

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITIONS

No. 326

Dated: 03-04-2025

It is certified that an inspection team headed by.....Amit Sharma.....

(Name of Officer and designation) from.....Chemist.....

Inspected the premises of Radiant Academy School, Mumrezpur Road
Hasanpur Laduki, Dist- Buland Shahr U.P on.....01-04-2025.....(Date of
 Inspection) and on the basis of Water Test report (attached) bearing
 No...326..... dated 01-04-2025 of 01-04-2026

It is certified that Radiant Academy Junior High School has safe drinking water
 facilities for the students and members of staff of the institution. School is also
 maintaining hygienic condition in the School building and campus as per norms
 prescribed by the Central/State Government.

This Certificate is valid up to...one year

For RADIANT ACADEMY SCHOOL

Rashmi Prasad
Manager

Signature and Seal

Name: Amit Sharma

Designation: Chemist

Name and address of Office-U.P Jal Nigam
(Rural) Bulandshahr

To

Radiant Academy School
 Mumrezpur Road,
 Hasanpur Laduki
 Dist- Buland shahr. U.P

Rashmi Prasad
 Principal
 Radiant Academy School
 Hasanpur, Laduki



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय
उ०प्र० जल निगम (ग्रामीण),
विकास भवन द्वितीय तल-336 बुलन्दशहर

क:- 326

1. धौ-7

1 07

दिनांक:- 01/04/2025

विकास खण्ड	ग्राम पंचायत का नाम	राजस्व ग्राम का नाम	स्थल का नाम	भौतिक परीक्षण				रासायनिक परीक्षण (पी० पी० एम०)						
				पी० एच०	टी० डी० एस०	टर्बिडिटी	रंग	क्लोराईड	सम्पूर्ण कठोरता	एल्कालिनिटी	आयरन	नाइट्रेट	फ्लोराइड	जीवाणु
				6.5-8.5	500-2000	0-5		250-1000	200-600	200-600	0.3-1.0	0-45	1-1.5	0.01-0.05
2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
खुर्जा	हसनपुर लडुकी	हसनपुर लडुकी	रेडियंट एकेडमी स्कूल हसनपुर लडुकी	7.05	230.5	0.012	रंगहीन	90	260	280	0.50	10.0	0.0	0.0

Rashmi Prasad
Principal
Radiant Academy School
Hasanpur, Laduki

For RADIANT ACADEMY SCHOOL

Rashmi Prasad
Manager

IF (Lab)

AE (Lab)